



MAYOR
John W. Minto

CITY COUNCIL
Ronn Hall
Stephen Houlahan
Brian W. Jones
Rob McNelis

March 22, 2018

CITY HALL WOOD REPLACEMENT-REPAIRS CIP 2018-38

ADDENDUM NO. 1

To Prospective Bidder(s):

This Addendum No. 1, two (2) 2 pages in total including cover letter forms an essential part of the contract documents by revising the Plans and Specifications with the following:

1A CONTRACT DOCUMENTS

No Changes

1B SPECIFICATIONS

210-1.3 Paint Coats

Delete the second sentence of the first paragraph and replace with the following:
All "sides" of cement fiber siding, lumber and glulams shall be painted with the exception of the "backside".

210-1.3 Paint Coats

Delete the second sentence of the second paragraph and replace with the following:

All wood joints shall be caulked with a polyurethane caulk. Caulking shall be rated for exterior and shall be clear. Caulking at joints shall be painted the same color as the wood.

210-2.3 Paint Coats

Delete the second sentence of the third paragraph and replace with the following:

All wood joints shall be caulked with a polyurethane caulk. Caulking shall be rated for exterior and shall be clear. Caulking at joints shall be painted the same color as the wood.

1C DRAWINGS
No Changes

1D RFI RESPONSES
None

Receipt of this addendum shall be acknowledged by attaching and/or indicating as such on the Information Required of Bidder to the submitted Bid Documents.



Toby Espinola, P.E.
Senior Civil Engineer